

Building

**GOVERNMENT OF ASSAM**  
**OFFICE OF THE EX. ENGINEER, PWD GUWAHATI BUILDING DIVISION-II,**  
**DISPUR, GUWAHATI.**

**BUILDING SAFETY CERTIFICATE**

Name of Organization / School : Delhi Public School, Kamrup  
Name of Owner : Mr. Manoj Anand.  
Location : Village- Nagaon, Baihata Chariali, Kamrup.  
Revenue survey No. : (Plot No. (s)/Survey No. 121,77,08,03,206,99,252293,113,116 and 254 (s) Khasra No. (s) 177,1129,180,179,1130,1540,1153,1152,1146,1215,1154, 1107,1106,178,181,184,194,183,182,1126,1127,1128 and 09 (Old) 1247 (New) at Village. Nagaon, P.O. Baihata Chariali, P.S.- Baihata Chariali, Dist. Kamrup, Assam.  
Type of Structure : R.C.C.  
Year of Construction : 2015-16.

This is to certify that the partially constructed building of above mentioned School Building was inspected by me on 04-09-2017 as per prevailing engineering norms conforming to relevant Indian Standard Codes of practice and safety against earthquakes as per IS- Code 1893.

The Property is situated in Revenue Survey No. 121,77,08,03,206,99,252293,113,116 and 254 (s) Khasra No. (s) 177,1129,180,179,1130,1540,1153,1152,1146,1215,1154, 1107,1106,178,181,184,194,183,182,1126,1127,1128 and 09 (Old) 1247 (New) (Area of Land 27 Bigha, 09 Lecha = 122453 Sq Mts.) at Village. Nagaon, P.O. Baihata Chariali, P.S.- Baihata Chariali, Dist. Kamrup, Assam.

The property is proposed to consist of Gr. Fl = 4705.887 Sq M, 1<sup>st</sup> Fl = 4346.089 Sq M, 2<sup>nd</sup> Fl = 4201.676 Sq M, 3<sup>rd</sup> Fl = 3907.148 Sq M as per approved by President, Nagaon Gaon Panchayat.


At present a part of Gr. Fl, 1<sup>st</sup> Fl and 2<sup>nd</sup> Fl of the School Building are constructed as RCC frame structure containing RCC Pile Foundation. I have inspected the already completed part of Gr Fl and 1<sup>st</sup> Fl and almost completed part of 2<sup>nd</sup> Fl of the School Building at various levels. No failure in any of the structural elements like Beam, Slab, Columns etc was observed at the time of my inspection.

By the inspection of the site and considering the above points, I am in the Opinion that the already completed Building is stable and serviceable. The portion of the already constructed Building is Fit to be Utilised as a School Building.

This Opinion is given on the basis of visual observations. No specific tests are carried out.

The above is valid for a period of Ten Years from the date of issue.

Date : 05- 09 - 2017.  
Name : Dipak Kumar Barman, EE PWD  
Address : Guwahati Building Division- II, Dispur. Assam.  
Phone No. : 9435114856.

  
5-9-2017  
(DIPAK Kr. BARMAN)  
Executive Engineer, PWD  
Guwahati Building Division-II, Dispur